

STATE OF CALIFORNIA
Department of Corrections and Rehabilitation
INVITATION FOR BID

revised: 04/25/24

DUE DATE: June 23, 2026 @ 2:00PM		Responses must be delivered to Procurement Support at: Attn: Kim.Morden@cdcr.ca.gov or 9838 Old Placerville Road, Suite B Sacramento, CA 95827 by no later than 2:00 p.m. on the due date.		DELIVERY TIME ARO: (After Receipt of Order)	
Supplier name and address:		Solicitation No. _____ Rev. # _____ Date _____ FPCM-ASP-I001141-002-KM 02 06/16/2026 Ship to: Avenal State Prison Attn: Mark Summerford, CSII or Louie Alves, Property Controller 1 Kings Way Avenal, CA 93204		ARE YOU CLAIMING PREFERENCE AS A CALIFORNIA CERTIFIED SMALL BUSINESS? Yes _____ No _____ ARE YOU A NON-SMALL BUSINESS CLAIMING AT LEAST 25% SMALL BUSINESS SUBCONTRACTOR PREFERENCE? Yes _____ No _____ ARE YOU CLAIMING INCENTIVE AS A DISABLED VETERAN BUSINESS ENTERPRISE (DVBE) OR A NON-DVBE CLAIMING DVBE SUBCONTRACTOR INCENTIVE? Yes _____ No _____	
Contact: Phone: () Fax: () Email: _____					
Name (Print) ➤ _____ Title: ➤ _____ Signature: ➤ _____ Date: _____ Federal Employer Identification Number: ➤ _____ California Seller's Permit Number: ➤ _____		Return bid to: (Electronic Mail) Department of Corrections & Rehabilitation Procurement Support Kim.Morden@cdcr.ca.gov (Courier) Department of Corrections & Rehabilitation Procurement Support Attn: Kim Morden, Procurement Officer 9838 Old Placerville Road, Suite B Sacramento, CA 95827		Section 14838 et seq. Of the California government code requires that a 5% preference be given to bidders who qualify as a small business as a non-small business claiming 25% California certified small business participation for requirements see title 2, California code of regulations section 1896 et seq. The requirements for nonprofit veteran service agencies qualifying as a small business are contained in section 999.50 et sec. Of the military and veterans code. The purchasing authority for this acquisition is under the jurisdiction of California penal code 7000 (a)(b) and 7001 meeting the criteria as part of the master plan. conferred by statute upon the department of general services and the department – (refer to document 11 of the procurement file).	
DECLARATIONS UNDER PENALTY OF PERJURY: By signing above, with inclusion of the date of signature, the above signed bidder DECLARES UNDER PENALTY OF PERJURY under the laws of the State of California as follows: (1) (STATEMENT OF COMPLIANCE). The above signed has complied with the non-discrimination program requirements of Government Code 12990 and Title 2, California Administrative Code Section 8103, and such declaration is true and correct. (2) The National Labor Relations Board declaration set forth in Paragraph 43 of the General Provisions is true and correct. (3) If a claim is made for the small business preference, the information set forth within is true and correct.					
This is a product only or product and installation purchase for delivery to 1 Kings Way, Avenal, CA 93204. Product(s) must be quoted as described on this Invitation for Bid (IFB). Bids must be in accordance with IFB FPCM-ASP-I001141-002-KM and Attachments I, II (plans and specifications). Bidders must meet the minimum requirements identified in the attached specification in order to be considered for award of the purchase order. (Optional) There is a mandatory walk-thru for this purchase on May 27, 2026 @ 8:00am.					
ITEM NO.	QTY	UNIT	DESCRIPTION	UNIT PRICE	EXTENSION
AVENAL STATE PRISON REPLACE/RELOCATE (2) AHU & REPAIR METAL ROOFING- LAUNDRY, BLDG FOB DESTINATION PLEASE REFER TO PLANS AND SPECIFICATIONS (ATTACHED AS A SEPARATE DOCUMENT). DELIVERIES MAY BE MADE WITHIN THE SECURE PERIMETER AND REQUIRE GATE CLEARANCE. Addendum 02 - Documents questions and answers resulting from the mandatory walk-thru conducted on May 27, 2026. Those who attended may submit a bid to Kim.Morden@cdcr.ca.gov no later than 2:00pm, June 23, 2026. All other terms and conditions remain the same.					

INVITATION FOR BID CONTINUATION		Supplier Name:		Solicitation No. FPCM-ASP-I001123-M001-KM	Rev. 02
ITEM NO.	QTY	UNIT	DESCRIPTION		UNIT PRICE EXTENSION

QUESTIONS AND ANSWERS

1. Q: Are we replacing the full length of the panel or to where the seam is on the panel. Plans say replacing lower panel, if you replace just the lower, it will be harder to make the lap come together because they have to overlay each other and are seamed together. Also, there is a clip that holds panels down. All panels used seamer to clip together. May not line up correctly if lower section only. Easier to replace both panels for clean flap to seam both panels together.

A: (Field Response) It was requested from roof edge to ridge because of the lap issue.

A: (A&E Response) Full length panels are preferred.

2. Q: What is the R Value of the insulation?

A: (Field Response) A&E response is required.

A: (A&E Response) Match existing.

3. Q: How many down spouts on the front of the building?

A: (Field Response) Down spouts account for 6 down spouts.

A: (A&E Response) Coordinate with field.

4. Q: What is the roof gauge?

A: (Field Response) Roof gauge 22.

A: (A&E Response) See Specifications.

5. Q: Are we matching the gutter profile that's in the plans?

A: (Field Response) Match profile of gutter on plans or submit alternative for A&E review.

A: (A&E Response) Match profile of gutter on plans or submit alternative for A&E review.

6. Q: Are we replacing the rake? It's a trim piece on the end wall of the building. Don't have to, but wanted to know?

A: (Field Response) Re-use existing.

A: (A&E Response) Replace damaged fascia panels at all locations where rust that penetrates the panel occurs.

7. Q: There are (12) 2' metal roofing panels that are currently damaged. Vendor recommends replacing the extra 2 panels (for a total of 28' from the exterior wall) that will need to be removed to access the purlins below. They are not currently damaged, but will be damaged during removal to access the purlins. There is no way to remove the currently crimped panels without further damage.

A: (Field Response) Provide 15 panels, one more than suggested.

A: (A&E Response) Means and Methods, defer to Field.