

**ADDENDUM NO. ONE (1)**

---

Date: June 16, 2026 Engineer's Project No. E18-230S

PROJECT: City of Social Circle Walton Drive Emergency Repair and  
Corby Lane, Justin Court, Emily Lane Milling and Asphalt Replacement

Client: City of Social Circle

---

*This Addendum forms a part of the Contract Documents and Construction Drawings and modifies the original Bid Documents for the above referenced project. Total pages of this addendum is 2 pages.*

---

The following items shall take precedence over the specifications for the above named project and shall become a part of the contract documents.

**Clarification:**

Be advised the scope of this project has been revised. The project will now include **only the Walton Drive portion of the original bid package**. All other portions of the original bid are excluded from this solicitation.

Bidders shall base their proposals solely on the Walton Drive work as identified in the revised bid documents. A **revised Bid Form** is attached and shall be used when submitting bids.

**Questions**

- Q1. The tonnage for the 12.5mm on Walton Drive does not match the Sy for the milling. Is the 12.5mm going back at 2" or 1.5"?
- A1. ***12.5mm shall be installed at 2" depth. Quantity of Asphalt Paving updated to 275 TN on attached Revised Bid Form.***

**Attachments**

*Revised Bid Form*

**PLEASE NOTE:** Contractors should acknowledge receipt of this Addendum.

**END OF ADDENDUM NO. ONE (1)**

**REVISED BID FORM**  
**WALTON DRIVE EMERGENCY REPAIR AND**  
**CORBY LANE, JUSTIN COURT, EMILY LANE MILLING AND ASPHALT REPLACEMENT**

**DUE:** 2:00 p.m., 30th day of June, 2026

**WALTON DRIVE EMERGENCY REPAIR**

| Item Description                                   | Quantity | Units | Unit Price | Unit Price Bid |
|----------------------------------------------------|----------|-------|------------|----------------|
| Mill Asphalt Pavement, 2 Inch Depth                | 2,410    | SY    | \$         | \$             |
| Asphalt Paving – 12.5mm Superpave, 2 Inch Depth    | 275      | TN    | \$         | \$             |
| Concrete Driveway Cut & Repair                     | 100      | SY    | \$         | \$             |
| Concrete Sidewalk Restoration (Match Existing)     | 50       | SY    | \$         | \$             |
| Permanent Seeding (Ds3)                            | 500      | LF    | \$         | \$             |
| Sod Restoration (Ds4) (Match Existing)             | 500      | SF    | \$         | \$             |
| Concrete Curb & Gutter Replacement(Match Existing) | 100      | LF    | \$         | \$             |
| Traffic Control                                    | 1        | LS    | \$         | \$             |
| <b>Total Bid Amount</b>                            |          |       |            | <b>\$</b>      |

The amount of Total Bid (Write in Words):

\_\_\_\_\_ Dollars (\$\_\_\_\_\_)

Bid received from: (Company) \_\_\_\_\_

(Address) \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_  
Authorized representative  
(Print or type name and title)

\_\_\_\_\_  
Authorized Representative  
(Signature)