

DRAWING RELEASE SUMMARY	
DATE	NO DESCRIPTION
02/29/08	ΔΔ M.P.E. COORDINATION
04/17/08	ΔΔ AS#407 REVISIONS TO FIRE ALARM DEVICES
04/28/08	ΔΔ RFI #887 ELECTRICAL FOR RTU DE3
05/16/08	ΔΔ REV #24 FIRE MARSHAL REVIEW COMMENTS



NOTES:

- PROVIDE IN EACH CONDUIT NOT OTHERWISE NOTED, TWO #12 AND ONE #10 GROUND. THIS INCLUDES ALL SWITCH LEGS, LIGHTING AND RECEPTACLE CIRCUITS.
- UNLESS OTHERWISE NOTICED, EXTEND 3/4" FROM EACH TELEPHONE OUTLET AND 5/8" UP ABOVE AN ACCESSIBLE CEILING.
- UNLESS OTHERWISE NOTICED, EXTEND 3/4" FROM EACH COMPUTER OUTLET AND 5/8" UP ABOVE AN ACCESSIBLE CEILING.
- UNLESS OTHERWISE NOTICED, EXTEND 3/4" FROM EACH COMBINATION TELEPHONE OUTLET AND 5/8" UP ABOVE AN ACCESSIBLE CEILING.
- UNLESS OTHERWISE NOTICED, EXTEND 3/4" FROM EACH TELEVISION (CATV) OUTLET AND 5/8" UP ABOVE AN ACCESSIBLE CEILING.
- UNLESS OTHERWISE NOTICED, EXTEND 3/4" FROM EACH TELEVISION (CATV) OUTLET AND 5/8" UP ABOVE AN ACCESSIBLE CEILING.
- ALL COVERS/PLATES ON EMERGENCY SHALL BE RED WITH STAINLESS STEEL COVERPLATE. ALL COVERS/PLATES IN SECURE AREA SHALL HAVE A SECURITY COVERPLATE - COVERS/PLATES IN SECURE AREA SHALL BE BLACK WITH STAINLESS STEEL COVERPLATE. FOR THE SECURE AREA DESIGNATION, SEE THE SECURITY PLAN.
- PLANS

N SECURED PORTIONS OF THE BUILDING, MANUAL FIRE ALARM BOXES SHALL BE LOCATED AT A CONSTANTLY ATTENDED LOCATION (CENTRAL CONTROL TOWER, CONTROL TOWER 2045 AND CONTROL TOWER 208) PER NFPA 101 2000TH EDITION CHAPTER 22.3.4.2 EXCEPTION NO. 2. THE INMATE NOTIFICATION SYSTEM SHALL BE ARRANGED TO ALARM AT THESE CONSTANTLY ATTENDED LOCATIONS ONLY AND SHALL NOT BE REQUIRED TO ACCOMPLISH GENERAL INMATE NOTIFICATION PER NFPA 101 2000TH EDITION CHAPTER 22.3.4.3.1 EXCEPTION.

LEGEND NOTES: (APPLIES TO SHEETS E-3.1 AND E-3.2)

- [illegible]

MATCH LINE-AREA C
MATCH LINE-AREA A