



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION

MAIL CODE 401-02B

DIVISION OF WATER QUALITY

BUREAU OF PRETREATMENT AND RESIDUALS

401 E. STATE STREET, P.O. BOX 420

TRENTON, NJ 08625-0420

www.state.nj.us/dep/dwq

PHILIP D. MURPHY

Governor

SHEILA Y. OLIVER

Lt. Governor

CATHERINE R. McCABE

Commissioner

VIA EMAIL TO: maryjo.kurtiak@dhs.state.nj.us

December 01, 2018

MARY JO KURTIK, DIRECTOR NJDHS
NJDHS OFFICE OF PROPERTY MANAGEMENT & CONST
PO BOX 700 - 222 S WARREN ST
CAPITAL PLACE ONE
TRENTON, NJ 08625-0700

Re: Residual General Permit Authorization Renewal
Cat: S2G -Sludge Quality Category 2 (GP)
NJPDES Permit No.: NJG0212032, Program Interest No.: 46697
GREYSTONE PARK PSYCH HOSPITAL
Parsippany-Troy Hills, Morris County

Dear Mary Jo Kurtiak:

Enclosed is New Jersey Pollutant Discharge Elimination System (NJPDES) Authorization to Discharge No. NJG0212032 (Category S2G -Sludge Quality Category 2 (GP)) issued under the authority of Residual NJPDES General Permit No. NJ0211672. Permit conditions are described herein and the General Permit is available for viewing at www.state.nj.us/dep/dwq/gp_residuals.htm.

A copy of this Authorization should be located at the regulated facility at all times and be available for inspection by any authorized representative of the Department. If you have designated an agent, you must notify them about this General Permit Authorization and its requirements.

If you have any questions or comments regarding the above referenced action, please contact Fayard Ali by telephone at (609) 984-4428 or Fayard.Ali@dep.nj.gov.


Sincerely,

Anthony Pilawski, Section Chief
Bureau of Pretreatment and Residuals
Water Pollution Management Element

Enclosures

c: Ted Wardencki, NJDHS [tadeusz.wardencki@dhs.state.nj.us]
Mark Burton, JES [mburton328@gmail.com]
Eric Williams, Licensed Operator [ewilliams@j-e-s.us]
Mike O'hagan, NJDHS [mohagan@northstar.com]
Chris Brindle, NJDEP Northern Enforcement [chris.brindle@dep.nj.gov]

Gpcv_res.doc



New Jersey Department of Environmental Protection

Mail Code 401-02B

Bureau of Pretreatment and Residuals

401 E. State Street, P.O. Box 420

Trenton, NJ 08625-0420

(609) 633-3823

AUTHORIZATION TO DISCHARGE
S2G -Sludge Quality Category 2 (GP)

Facility Name: GREYSTONE PARK PSYCH HOSPITAL

Permit Number: NJG0212032

Program Interest No.: 46697

Facility Address:

PLANT RD

GREYSTONE PARK, NJ 07950

Type of Activity: Residual General Permit Authorization Renewal

Owner:

NJDHS OFFICE OF PROPERTY MANAGEMENT & CONST

PO BOX 700 - 222 S WARREN ST

CAPITAL PLACE ONE

TRENTON, NJ 08625-0700

Operating Entity:

NJDHS OFFICE OF PROPERTY MANAGEMENT & CONST

PO BOX 700 - 222 S WARREN ST

CAPITAL PLACE ONE

TRENTON, NJ 08625-0700

Issuance Date:

12/01/2018

Effective Date:


01/01/2019

Expiration Date:

12/31/2023

Your Request for Authorization under NJPDES General Permit No. NJ0211672 has been approved by the New Jersey Department of Environmental Protection.

This Authorization to Discharge implements the provisions of the Sludge Quality Assurance Regulations (N.J.A.C. 7:14C) for residual quality and quantity monitoring as well as other general conditions required by N.J.A.C. 7:14A-6 for Domestic Treatment Works that have a permitted flow from 0.1 to 0.999 MGD.


Anthony Pilawski, Section Chief

Bureau of Pretreatment and Residuals

Date: 12/01/2018

(Terms, conditions and provisions attached hereto)

Division of Water Quality

PART I GENERAL REQUIREMENTS: NJPDES

A. General Requirements of all NJPDES Permits

1. Requirements Incorporated by Reference

- a. The permittee shall comply with all conditions set forth in this permit and with all the applicable requirements incorporated into this permit by reference. The permittee is required to comply with the regulations, including those cited in paragraphs b. through e. following, which are in effect as of the effective date of the final permit.
- b. General Conditions
 - Penalties for Violations N.J.A.C. 7:14-8.1 et seq.
 - Incorporation by Reference N.J.A.C. 7:14A-2.3
 - Toxic Pollutants N.J.A.C. 7:14A-6.2(a)4i
 - Duty to Comply N.J.A.C. 7:14A-6.2(a)1 & 4
 - Duty to Mitigate N.J.A.C. 7:14A-6.2(a)5 & 11
 - Inspection and Entry N.J.A.C. 7:14A-2.11(e)
 - Enforcement Action N.J.A.C. 7:14A-2.9
 - Duty to Reapply N.J.A.C. 7:14A-4.2(e)3
 - Signatory Requirements for Applications and Reports N.J.A.C. 7:14A-4.9
 - Effect of Permit/Other Laws N.J.A.C. 7:14A-6.2(a)6 & 7 & 2.9(c)
 - Severability N.J.A.C. 7:14A-2.2
 - Administrative Continuation of Permits N.J.A.C. 7:14A-2.8
 - Permit Actions N.J.A.C. 7:14A-2.7(c)
 - Reopener Clause N.J.A.C. 7:14A-6.2(a)10
 - Permit Duration and Renewal N.J.A.C. 7:14A-2.7(a) & (b)
 - Consolidation of Permit Process N.J.A.C. 7:14A-15.5
 - Confidentiality N.J.A.C. 7:14A-18.2 & 2.11(g)
 - Fee Schedule N.J.A.C. 7:14A-3.1
 - Treatment Works Approval N.J.A.C. 7:14A-22 & 23
- c. Operation And Maintenance
 - Need to Halt or Reduce not a Defense N.J.A.C. 7:14A-2.9(b)
 - Proper Operation and Maintenance N.J.A.C. 7:14A-6.12
- d. Monitoring And Records
 - Monitoring N.J.A.C. 7:14A-6.5
 - Recordkeeping N.J.A.C. 7:14A-6.6
 - Signatory Requirements for Monitoring Reports N.J.A.C. 7:14A-6.9
- e. Reporting Requirements
 - Planned Changes N.J.A.C. 7:14A-6.7
 - Reporting of Monitoring Results N.J.A.C. 7:14A-6.8
 - Noncompliance Reporting
 - Hotline/Two Hour & Twenty-four Hour Reporting N.J.A.C. 7:14A-6.10 & 6.8(h)
 - Written Reporting N.J.A.C. 7:14A-6.10(e) & (f) & 6.8(h)
 - Duty to Provide Information N.J.A.C. 7:14A-2.11, 6.2(a)14 & 18.1
 - Schedules of Compliance N.J.A.C. 7:14A-6.4
 - Transfer N.J.A.C. 7:14A-6.2(a)8 & 16.2

PART II

GENERAL REQUIREMENTS: DISCHARGE CATEGORIES

A. Additional Requirements Incorporated By Reference

1. General Discharge Requirements

- a. The permittee shall comply with land-based sludge management criteria and shall conform with the requirements for the management of residuals and grit and screenings under N.J.A.C. 7:14A-6.15(a), which includes:
 - i. Standards for the Use or Disposal of Residual, N.J.A.C. 7:14A-20;
 - ii. Section 405 of the Federal Act governing the disposal of sludge from treatment works treating domestic sewage;
 - iii. The Solid Waste Management Act, N.J.S.A. 13:1E-1 et seq., and the Solid Waste Management Rules, N.J.A.C. 7:26;
 - iv. The Sludge Quality Assurance Regulations, N.J.A.C. 7:14C;
 - v. The Statewide Sludge Management Plan promulgated pursuant to the Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Solid Waste Management Act, N.J.S.A. 13:1E-1 et seq.;
 - vi. The provisions concerning disposal of sewage sludge and septage in sanitary landfills set forth at N.J.S.A. 13:1E-42 and the Statewide Sludge Management Plan; and
 - vii. Residual that is disposed in a municipal solid waste landfill unit shall meet the requirements in 40 CFR Part 258 and/or N.J.A.C. 7:26 concerning the quality of residual disposed in a municipal solid waste landfill unit. (That is, passes the Toxicity Characteristic Leaching Procedure and does not contain "free liquids" as defined at N.J.A.C. 7:14A-1.2.)

B. General Conditions

1. Scope

- a. The issuance of this permit shall not be considered as a waiver of any applicable federal, state, and local rules, regulations and ordinances.

2. Notification of Non-Compliance

- a. The permittee shall notify the Department of all non-compliance when required in accordance with N.J.A.C. 7:14A-6.10 by contacting the DEP HOTLINE at 1-877-WARNDEP (1-877-927-6337).
- b. The permittee shall report any noncompliance with the land-based sludge management criteria to the Department and to the ultimate sludge management alternative utilized by the permittee in accordance with Part IV, D.1.b of this permit.

3. Notification of Changes

- a. The permittee shall give written notice to the Department of any planned physical alterations or additions to the permitted facility when the alteration or addition is expected to result in a significant change in the permittee's discharge(s) and/or residual use or disposal practices. This includes, but is not limited to, any changes in the treatment process that would result in a change to: sludge quality, a monitored location, and/or addition of a monitored location.
- b. Prior to any change in ownership, the current permittee shall comply with the requirements of N.J.A.C. 7:14A-16.2, pertaining to the notification of change in ownership.

4. Permit Conditions Relating to Residuals Management

- a. If any applicable standard for residual use or disposal is promulgated under section 405(d) of the Federal Act and Sections 4 and 6 of the State Act and that standard is more stringent than any limitation on the pollutant or practice in the permit, the Department may modify or revoke and reissue the permit to conform to the standard for residual use or disposal.
- b. The permittee shall make provisions for storage, or some other approved alternative management strategy, for anticipated downtimes at a primary residual management alternative. The permittee shall not be permitted to store residual beyond the capacity of the structural treatment and storage components of the treatment works. N.J.A.C. 7:14A-20.8(a) and N.J.A.C. 7:26 provide for the temporary storage of residuals for periods not exceeding six months, provided such storage does not cause pollutants to enter surface or ground waters of the State. The storage of residual for more than six months is not authorized under this permit. However, this prohibition does not apply to residual that remains on the land for longer than six months when the person who prepares the residual demonstrates that the land on which the residual remains is not a surface disposal site or landfill. The demonstration shall explain why residual must remain on the land for longer than six months prior to final use or disposal, discuss the approximate time period during which the residual shall be used or disposed and provide documentation of ultimate residual management arrangements. Said demonstration shall be in writing, be kept on file by the person who prepares residual, and submitted to the Department upon request.
- c. The permittee shall comply with the appropriate adopted District Solid Waste or Sludge Management Plan (which by definition in N.J.A.C. 7:14A-1.2 includes Generator Sludge Management Plans), unless otherwise specifically exempted by the Department.
- d. The preparer must notify and provide information necessary to comply with the N.J.A.C. 7:14A-20 land application requirements to the person who applies bulk residual to the land. This shall include, but not be limited to, the applicable recordkeeping requirements and certification statements of 40 CFR 503.17 as referenced at N.J.A.C. 7:14A-20.7(j).
- e. The preparer who provides residual to another person who further prepares the residual for application to the land must provide this person with notification and information necessary to comply with the N.J.A.C. 7:14A-20 land application requirements.
- f. Any person who prepares bulk residual in New Jersey that is applied to land in a State other than New Jersey shall comply with the requirement at N.J.A.C. 7:14A-20.7(b)1.ix to submit to the Department written proof of compliance with or satisfaction of all applicable statutes, regulations, and guidelines of the state in which land application will occur.

5. Additional General Requirements

- a. This general permit may be issued, modified, revoked and reissued, or terminated in accordance with applicable requirements of N.J.A.C. 7:14A-15, 16 and 17.

- b. With the consent of the permittee, the Department shall revoke an authorization to discharge under this general permit without following the procedures set forth in N.J.A.C. 7:14A-15.6 if the discharge has ceased and provided that all applicable closure requirements as required by N.J.A.C. 7:14A-23.34 have been completed.

6. Requirements to Obtain an Individual Permit

- a. The Department may require any person authorized by this general New Jersey Pollutant Discharge Elimination System (NJPDES) permit to apply for and obtain an individual NJPDES permit. Cases in which an individual NJPDES permit may be required include the following:
 - i. The quantity and/or quality of the discharge changes such that site specific requirements are necessary;
 - ii. The permittee is not in compliance with the conditions of the general NJPDES permit;
 - iii. A change has occurred such that the source does not involve the same or substantially similar types of operating procedures; or
 - iv. A change has occurred such that the source does not require the same or similar monitoring.
- b. The Department may require any owner, operator and/or discharger authorized by this general NJPDES permit to apply for an individual NJPDES permit as provided above, only if the owner, operator, or discharger has been notified in writing that a permit application is required. This notice shall include a statement establishing a deadline by which the owner, operator, and/or discharger is to file the application, and a statement that on the effective date of the individual NJPDES permit the general NJPDES permit as it applies to the individual permittee shall be revoked.

7. Exclusions

- a. Any owner, operator, and/or discharger authorized by this general permit may request to be excluded from the coverage of the general NJPDES permit by applying for an individual permit. The owner, operator, and/or discharger shall submit an application in accordance with N.J.A.C. 7:14A-4, with reasons supporting the request, to the NJDEP. The request shall be processed under N.J.A.C. 7:14A-15, 16 and 17. The request shall be granted by the issuance of an individual permit if the reasons cited by the owner, operator and/or discharger are adequate to support the request.
- b. An owner, operator, and/or discharger excluded from this general NJPDES permit solely because of an existing individual permit, may request that the individual permit be revoked or modified, as appropriate, and that the discharge be authorized by the general NJPDES permit. Upon revocation or modification of the individual permit, the permittee shall be authorized under the general permit.

8. Administrative Requirements

- a. Persons seeking authorization under this general permit shall submit to the Department a written Request for Authorization (RFA). A RFA under this general permit shall include the following: A completed NJPDES 1 Form and a completed Form R.
- b. The Department may notify a person that the discharge is authorized by a general permit, even if the person has not submitted a RFA. A person so notified may nonetheless request an individual permit under B.7 above.

- c. Authorizations under this general permit shall become effective upon receipt of notification of authorization by the Department as allowed pursuant to N.J.A.C. 7:14A-6.13(d)5.iii.
- d. Upon reissuance of this general permit, authorizations shall be automatically renewed as allowed pursuant to N.J.A.C. 7:14A-6.13(d)9. However, the renewal of an authorization either requires a notice to the Department that there are no changes or a new RFA to be submitted to update any information that is no longer true, accurate and/or complete

9. Access

- a. The permittee shall allow an authorized representative of the Department, upon the presentation of credentials to enter upon a person's premises, for purposes of inspection, and to access/copy any records that must be kept under the conditions of this permit. The Department or its designated agent may take samples of sludge to verify the reported analytical data and to determine if the permittee is in compliance with this permit.

PART III

LIMITS AND MONITORING REQUIREMENTS

MONITORED LOCATION:SL2A SQAR Sludge Holding
TankDISCHARGE CATEGORY(IES):

S2G - Sludge Quality Category 2 (GP)

Location Description

SQAR samples shall be collected from the sludge being discharged from the sludge holding tank. Said samples shall be representative of the chemical and physical characteristics of the sludge leaving the treatment plant for use or disposal.

Contributing Waste Types

Dom Residual-Other

Residuals DMR Reporting Requirements:

Submit a Semi-Annual DMR: due 60 calendar days after the end of each calendar six months.

Table III - A - 1: Residuals DMR Limits and Monitoring Requirements**PHASE:** Final**PHASE Start Date:****PHASE End Date:**

Parameter	Sample Point	Limit	Limit	Units	Limit	Limit	Limit	Units	Frequency	Sample Type
Solids, Total	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	%TS	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Nitrate Nitrogen, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Nitrogen, Kjeldahl Total, Dry Wt	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Potassium Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			

Residuals DMR Reporting Requirements:

Submit a Semi-Annual DMR: due 60 calendar days after the end of each calendar six months.

Table III - A - 1: Residuals DMR Limits and Monitoring Requirements**PHASE:** Final**PHASE Start Date:****PHASE End Date:**

Parameter	Sample Point	Limit	Limit	Units	Limit	Limit	Limit	Units	Frequency	Sample Type
Nitrogen, Ammonia Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Calcium Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Molybdenum Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Phosphorus Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Arsenic, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Selenium, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Copper, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			

Residuals DMR Reporting Requirements:

Submit a Semi-Annual DMR: due 60 calendar days after the end of each calendar six months.

Table III - A - 1: Residuals DMR Limits and Monitoring Requirements**PHASE:** Final**PHASE Start Date:****PHASE End Date:**

Parameter	Sample Point	Limit	Limit	Units	Limit	Limit	Limit	Units	Frequency	Sample Type
Beryllium Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Cadmium, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Zinc, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Lead, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Nickel, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			
Mercury, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			

Residuals DMR Reporting Requirements:
Submit a Semi-Annual DMR: due 60 calendar days after the end of each calendar six months.

Table III - A - 1: Residuals DMR Limits and Monitoring Requirements										
PHASE: Final		PHASE Start Date:			PHASE End Date:					
Parameter	Sample Point	Limit	Limit	Units	Limit	Limit	Limit	Units	Frequency	Sample Type
Chromium, Dry Weight	Residuals	*****	*****	*****	*****	REPORT Monthly Average	*****	MG/KG	1/6 Months	Composite
January thru December	QL	***	***		***	***	***			

Residuals Transfer Reporting Requirements:

Submit a Monthly RTR: due 60 calendar days after the end of each calendar month.

MONITORED LOCATION:
SL2P SQAR Sludge Production

DISCHARGE CATEGORY(IES):
S2G - Sludge Quality Category 2 (GP)

Location Description

Production information shall be collected on all residuals leaving the treatment plant for use or disposal. All residuals removed from the treatment works during the reporting period must be reported on the Monitoring Report Forms (MRFs). If the permittee is removing residuals for use or disposal from a location other than the monitored location(s) in Part III of the permit, the permittee shall contact BPR prior to removal to determine if the residual should be reported on the existing MRFs or if a new monitored location should be added.

Contributing Waste Types

Dom Residual-Other

Residuals WCR - Annual Reporting Requirements:

Submit an Annual WCR: due 60 calendar days after the end of each calendar year.

Table III - B - 1: Residuals WCR - Annual Limits and Monitoring Requirements**PHASE:** Final**PHASE Start Date:****PHASE End Date:**

Parameter	Sample Point	Compliance Quantity	Units	Sample Type	Monitoring Period
Amt Sludge Rmvd, Gallons	Residuals	REPORT	GAL/YEAR	Calculated	January thru December
Total Amount of Sludge Removed	Residuals	REPORT	DMT/YR	Calculated	January thru December
Solids, Total	Residuals	REPORT	%TS	Composite	January thru December

PART IV

SPECIFIC REQUIREMENTS: NARRATIVE

Notes and Definitions

A. Footnotes

1. Statistical Base Limit

- a. Monthly Average - report the arithmetic mean of all samples taken during that month.

2. Sample Type

- a. Composite - a minimum of five (5) grab samples of equal volumes shall be taken to form a representative composite of residual quality in accordance with N.J.A.C. 7:14C-1.6.

B. Definitions

1. Definitions

- a. All words and terms used in this permit shall have meanings as defined in the "Regulations Concerning the New Jersey Pollutant Discharge Elimination System" (N.J.A.C. 7:14A), unless otherwise stated or unless the context clearly requires a different meaning.
- b. "Land-based sludge management criteria" means those standards established by the Department in the Statewide Sludge Management Plan adopted pursuant to the Solid Waste Management Act, N.J.S.A. 13:1E-1 et seq., or established pursuant to the Clean Water Act or the Federal Water Pollution Control Act (33 U.S.C. Section 1251 et seq.) including all subsequent supplements and amendments, or any regulations adopted pursuant thereto.
- c. "Sludge" means the solid residue and associated liquid resulting from physical, chemical, and/or biological treatment of domestic or industrial wastewaters.
- d. "Treatment works" means any treatment works as defined by N.J.A.C. 7:14A-1.2 and N.J.S.A. 58:10A-3.
- e. "Ultimate sludge management alternative" means the final management of sludge at a facility or operation such that no additional permit or approval actions are required for further processing or movement.

Sludge Quality Category 2 (GP)

A. Sludge Quality Requirements

1. Residuals Information

- a. The parameters required to be monitored are specifically stated under Part III of this permit.
- b. All sludge samples shall be collected at locations representative of the chemical and physical characteristics of the sludge removed from the last treatment process before leaving the treatment plant for use or disposal.
- c. Where a treatment works generates several different types of sludges (for example, primary, secondary or advanced wastewater treatment sludges) each of which is removed separately for use or disposal, separate composite samples for each different type of sludge shall be analyzed for the parameters under Part III of this permit.
- d. All residuals removed from the treatment works during the reporting period must be reported on the RTR. If the permittee is removing residuals for use or disposal from a location other than the monitored location in Part III of the permit, the permittee shall contact BPR prior to removal to determine if the residual should be reported on the existing MRF's or if a new monitored location should be added.
- e. A sludge sampling plan that details the sampling and analytical procedures pursuant to N.J.A.C. 7:14C-1.6(c) shall be developed and maintained for all parameters under Part III of this permit.
- f. All sample collection, preservation and analysis shall be performed in a manner consistent with the Sludge Quality Assurance Regulations (N.J.A.C. 7:14C).
- g. All monitoring required by this permit shall be performed by a laboratory certified by the Department for the analysis of those specific parameters in accordance with N.J.A.C. 7:18.
- h. All sample frequencies expressed in Part III are minimum requirements. If the permittee monitors any parameter more frequently than required by this permit and uses the test procedures contained herein, the results of this monitoring shall be included in the calculation and reporting of the data submitted. Such increased frequency shall also be indicated.

B. Recordkeeping

1. Standard Recordkeeping Requirements

- a. The permittee shall retain copies of all reports required by a NJPDES permit and records of all data used to complete the application for a NJPDES permit for a period of at least 5 years.

2. Residuals Information

- a. In addition to the information required under Part III, the permittee shall retain the following information for a period of at least five (5) years:
 - i. All records of the monitoring information, and quality assurance and quality control documentation specified in N.J.A.C. 7:14C-1.4(f).
 - ii. Records on the quality of all residual received pursuant to the Sludge Quality Assurance Regulations at N.J.A.C. 7:14C.

C. Reporting

1. Residuals Information

Sludge Quality Category 2 (GP)

- a. The frequency of reporting to the Department of the records kept under Part III shall be as specifically stated therein.
- b. The permittee shall report monitoring results on the Discharge Monitoring Reports (DMR), Waste Characterization Reports (WCR), Residuals Transfer Reports (RTR), or other monitoring report forms, where specified, and all applicable information required on the forms shall be entered in the manner specified therein before submission. Any information not in compliance with this condition shall not be deemed to fulfill the reporting requirements of this permit.
- c. All monitoring report forms must be electronically submitted to the Department's MRF submission service. Within 180 days after the effective date of a new notice of authorization issued under this permit, the permittee must enroll in the NJDEP Electronic Data Interchange (EDI) reporting program to submit monitoring report forms noted in C.1.b above through the NJDEP Online Web Site. The permittee must enroll at www.njdeponline.com. Until such time as your NJPDES EDI agreement is executed paper monitoring report forms will be provided to you by the Department and shall be submitted to Mail Code 401-02B, Division of Water Quality, Bureau of Pretreatment and Residuals, Permit Administration Section, P.O. Box 420, Trenton, New Jersey 08625-0420.
- d. Submit any modifications to the sludge sampling plan required pursuant to Section A.1.e above within thirty (30) days of any subsequent sampling plan modification. The sludge sampling plan modification shall be submitted to: Mail Code 401-02B, Division of Water Quality, Bureau of Pretreatment and Residuals, P.O. Box 420, Trenton, New Jersey 08625-0420

D. Operation and Management

1. Residuals Information

- a. The permittee shall comply with the land-based sludge management criteria applicable to the ultimate sludge management alternative utilized by the permittee. It shall be the responsibility of the permittee to ensure that all residual accepted is compatible with the land-based sludge management criteria applicable to the ultimate sludge management alternative utilized by the permittee.
- b. The permittee shall report any noncompliance with the land-based sludge management criteria to the Department. The noncompliance with the land-based sludge management criteria shall be orally reported within 24 hours of the permittee becoming aware of the noncompliance to the Bureau of Pretreatment and Residuals at (609) 984-4428 and to the ultimate sludge management alternative. A written submission shall be made within five days thereafter to: Mail Code 401-02B, Division of Water Quality, Bureau of Pretreatment and Residuals, P.O. Box 420, Trenton, New Jersey 08625-0420, with a copy to the ultimate sludge management alternative, and shall include the following information:
 - i. Dates of occurrence;
 - ii. A description of the noncompliance with the land-based sludge management criteria;
 - iii. The cause of the noncompliance; and
 - iv. Steps being taken to reduce, eliminate and prevent reoccurrence of the noncompliance.

- c. Based on information submitted pursuant to (b) above, or pursuant to N.J.A.C. 7:14A-20.5, the Department may require the permittee to perform and submit the results of additional sludge analyses, obtain under N.J.A.C. 7:26G a formal waste classification of the sludge removed for use or disposal, and/or require other actions when necessary to protect public health or the environment from any adverse effect of a pollutant in the sludge.

2. Acceptance of Customer Residuals by Treatment Works located in New Jersey

- a. Prior to accepting a residual source that has not been issued an Authorization under one of the New Jersey Sludge Quality Assurance Regulation (SQAR) General Permits, the permittee shall submit a completed Domestic or Industrial Generator Form R (whichever is applicable), signed by a duly authorized representative of the residual generator.
- b. The permittee has one hundred eighty (180) days from the effective date of this permit to submit a completed Form R from a residual source that is currently being accepted and has not been issued an Authorization under one of the New Jersey Sludge Quality Assurance Regulation (SQAR) General Permits.
- c. The permittee is prohibited from receiving residual sources that do not have a completed Form R on file with the Department pursuant to (a) and (b) above.

3. Closure Requirements for Treatment Works located in New Jersey

- a. The permittee shall follow the closure procedures at N.J.A.C. 7:14A-23.34.
- b. All residual material shall be removed within 180 calendar days after the treatment works and/or equipment is taken out of service.
- c. Proof of proper residual management shall be submitted within thirty (30) calendar days after their removal from a closed unit.

GREYSTONE PARK PSYCH HOSPITAL, Greystone Park

Permit No.NJG0212032
RES180001 Residual General Permit Authorization Renewal