WC Eshenaur and Son INC - RFI 01

---Where is the existing building located that has the HVAC equipment to be relocated?

---Cross section of duct to be reinforced>>>is that including length or just W x H and if duct is TDC is that sufficient for reinforcing?

Duct Reinforcement shall meet the requirements of SMACNA 006, chapter 2. Reinforcement requirements are dependent on duct pressure class, duct dimensions, duct material thickness, hanger spacing and joist type, see addendum #2 sheet M501 for revisions. Duct constructed with TDC joints shall be reinforced as required by SMACNA.