REQUEST FOR INFORMATION

RFI# 06

Please type or print legibly

TO: Tina Rebuck

FROM: eciConstruction

DATE: 6/3/2026
RE: CONTRACT NO. 42260052

TITLE: SOF Construct Simulator Facility
LOCATION: PA Air National Gaurd

SUBJECT: Line Stripping
SPEC.REF. 321713
DWG.REF.

PRIORITY: [✓] 48 Hours
[ ] Routine (10) Days

INFORMATION REQUIRED:

Is Sherwin Williams line paint acceptable for parking lines?

Glass Beads are listed in the spec. Are these required on all painted lines? If not, where are they needed?

Thermoplastic line paint is mentioned in the spec, is this required on this project? If so, please indicate where.

Distribution: DMVA Project Manager, DMVA FCMM

REPLY

Be sure to indicate on form whether change order is required. Answer RFI without delay.

FROM: Corey Bray DATE: 06/05/2026

1. In the design the contractor can request a substitution to use a paint not listed in the specifications and we will review at that time if the paint meets the code requirements as listed in the specifications.

2. Glass beads are required as per specification 32 17 23.

3. Specification 32 17 23 includes specifications for painted pavement markings as well as thermoplastic pavement markings. The contractor can choose to use either product for the pavement markings on the site.

_____ A response is appended to this RFI, since a more detailed explanation is required.

Distribution: **DMVA Project Manager**
DMVA CONTRACTING OFFICER
DMVA Professional
Contractor(s)
Other: _____