REQUEST FOR INFORMATION

RFI# 2 **Please type or print legibly**

TO: Owner

DATE: 6/10/2026
RE: CONTRACT NO. SHYQ149104

TITLE:
LOCATION:

FROM: GR Sponaugle

SUBJECT:
SPEC.REF.
DWG.REF. E701 E702

PRIORITY: [ ] 48 Hours
[x] Routine (10) Days

INFORMATION REQUIRED:

Confirm SPD size and wire size for PANEL LDP - One-line on E701 Shows 60A – Panel Schedule on E702 shows 30A

Fed by 4#10

Distribution: DMVA Project Manager, DMVA FCMM

REPLY

Be sure to indicate on form whether change order is required. Answer RFI without delay.

FROM: Robert L Pryor DATE: 6/15/2026

E702 is correct.

_____ A response is appended to this RFI, since a more detailed explanation is required.

Distribution: DMVA Project Manager
DMVA CONTRACTING OFFICER
DMVA Professional
Contractor(s)
Other: _____