

ATTACHMENT # 1
T2546 VAPOR RECOVERY SYSTEMS
GASOLINE TANKS FOR NJDOT
NORTH REGION

LOCATION	QUANTITY			TANK SIZE	TYPE OF FUEL	AST	UST	STAGE II VAPOR RECOVERY SYSTEMS					AVERAGE MONTHLY OUTPUT (Jan 2016 - Aug 2017)	TESTS TO BE PERFORMED & FREQUENCY					FACILITY ID NUMBER	PERMIT EXPIRES	
								Balance Systems			Vacuum Assisted	Other or No Stage II		Balance Systems			Vacuum Assisted Systems				
	Tanks	Dispensers	Nozzles per Dispenser					Gasboy Astra System	"U" Fuel Tank w/Suction Fuel Pump	Gravity System	(Submersible Pump w/Dispenser)			CARB TP-201.3	CARB TP-201.2B	CARB TP-201.4	CARB TP-201.5				
																	Static Pressure Performance Test (Pressure Decay)	Pressure / Vacuum Vent Valve Test	Dynamic Back Pressure Test (Flow & Blockage)	Air to Liquid Volume Ration Test	Vacuum Integrity Test (Healy Systems)
Branchville	1	1	2	8,000	G		X			X			4,680	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8303	4/19/2022	
	1	1	2	4,000	D	X															
Clifton	1	1	1	6,000	G	X					X		6,394	*	*	*	*	*	H3014	4/20/2022	
	1	1	1	4,000	D	X															
Columbia	1	2	2	4,000	G	X					X		6,011	12 MO.	12 MO.				H8728	4/20/2022	
	1	2	2	6,000	D	X															
Elizabeth	1	1	1	4,000	D	X			X												
Ft. Lee	1	1	1	4,000	D	X			X					*	*	*		*			
Hackettstown	1	1	1	1,000	D	X															
Hanover	1	2	1	6,000	G	X							12,265	*	*	*		*	H2518	11/17/2020	
	1			4,000	G	X															
	1	1	1	6,000	D	X															
Jersey City	1	1	2	6,000	G	X					X		7,504	12 MO.	12 MO.	36 MO.			H8725	7/7/2021	
	1	1	2	6,000	D	X															
Lafayette	1	1	1	6,000	G	X					X		7,206	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8306	4/21/2022	
	1	1	1	6,000	D	X															
Lodi	2	1	2	6,000	G	X					X		11,879	12 MO.	12 MO.				H0001	7/7/2021	
		1	1	6,000	G	X					X										
	1	1	1	6,000	D	X															
Netcong	1	2	1	10,000	G		X			X	X		17,212						H2537	4/20/2022	
	1	1	1	12,000	D		X														
Newark	1	2	1	6,000	G	X						X	26,280	*	*	*		*	H0544	7/7/2021	
	1	2	1	6,000	G	X						X									
	1	2	1	6,000	D	X															
Paterson	1	1	1	4,000	G	X						X	4,663	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8738	4/21/2022	
	1	1	1	4,000	D	X															
Ramsey	1	1	2	4,000	G	X							1,086	*	*	*		*	H8737	6/8/2017	
				4,000	D																
Riverdale	1	1	1	6,000	G	X						X	4,348	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H2566	4/19/2022	
	1	1	1	6,000	D	X															
Rockaway	1	1	1	4,000	G	X						X	3,645	*	*	*		*	H2548	5/13/2018	
	1	1	1	4,000	D	X															
Springfield-Summit	1	1	1	4,000	G	X			X			X	3,172	*	*	*		*	H8803	6/8/2017	
	1	1	1	4,000	D	X			X												
Sussex	1	1	1	500	G	X							646	12 MO.	12 MO.				H8309	6/12/2016	
	1	1	1	4,000	D	X			X												
Totowa	1	1	2	4,000	G		X			X			26,701	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H3064	4/21/2022	
				8,000	G		X			X											
				8,000	D		X			X											
Washington Port Coldon	1	1	1	6,000	G	X						X	8,840	12 MO.	12 MO.	36 MO.			H8517	7/7/2021	
	1	1	1	6,000	D	X															
West Orange	1	1	1	4,000	G	X			X			X	2,938	*	*	*		*	H0545	4/21/2022	
	1	1	1	4,000	D	X			X												
Yellow Frame	1	1	1	4,000	G	X			X			X	1,348	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8513	4/19/2022	
	1	1	1	2,000	D	X			X												

**ATTACHMENT # 1
T2546 VAPOR RECOVERY SYSTEMS
GASOLINE TANKS FOR NJDOT
CENTRAL REGION**

Last Updated: 8/20/2018

LOCATION	QUANTITY			TANK SIZE	TYPE OF FUEL	AST	UST	STAGE II VAPOR RECOVERY SYSTEMS					AVERAGE MONTHLY OUTPUT (Jan 2016 - Aug 2017)	TESTS TO BE PERFORMED & FREQUENCY					FACILITY ID NUMBER	PERMIT EXPIRES	
														Balance Systems			Vacuum Assisted Systems				
	Tanks	Dispensers	Nozzles per Dispenser					Gasboy Astra System	"U" Fuel Tank w/Suction Fuel Pump	Gravity System	(Submersible Pump w/Dispenser)	Other or No Stage II		CARB TP-201.3	CARB TP-201.2B	CARB TP-201.4	CARB TP-201.5				
														Static Pressure Performance Test (Pressure Decay)	Pressure / Vacuum Vent Valve Test	Dynamic Back Pressure Test (Flow & Blockage)	Air to Liquid Volume Ration Test	Vacuum Integrity Test (Healy Systems)			
Bedminster	1	1	1	6,000	G	X				X			9,292							H3506	5/13/2018
	1	1	1	6,000	D	X															
Bloomsbury	1	1	2	2,000	G	X					X		9,075							H8729	4/1/2018
	1	1	2	4,000	D	X															
Bridgewater	2	1	2	6,000	G	X					X		22,871							H3539	7/7/2021
				6,000	G	X															
	1	1	2	6,000	D	X															
	1	1	1	4,000	D	X															
Clinton	1	1	1	6,000	G	X				X			11,390							H8007	7/7/2021
	1	1	1	4,000	D	X															
College Farm	1	1	2	6,000	G	X				X			8,316							H1553	7/7/2021
	1	1	2	6,000	D	X															
Fernwood	2	2	2	10,000	G		X						35,020							60090	4/21/2022
				10,000	G		X														
	1	1	2	10,000	D		X														
Flemington	1	2	1	6,000	G	X							9,967							H8009	
	1	2	1	4,000	D	X															
Freehold	2	1	2	6,000	G	X					X		10,496							H2044	7/7/2021
				6,000	G	X															
	1	1	2	6,000	D	X															
Hamilton	2	2	1	6,000	G	X					X		16,753							H6056	7/7/2021
				6,000	G	X															
	1	1	1	6,000	D	X															
Hazlet	1	1	1	4,000	D	X					X										
Keasbey	1	1	2	4,000	G		X			X			20,276							H8755	5/9/2018
	1	1	2	6,000	D		X			X											
Lakewood	2	4	1	6,000	G	X						X	7,986							H7895	7/7/2021
				6,000	G	X						X									
	1	2	1	6,000	D	X															
Lawrence	1	1	1	6,000	G	X						X	8,704							H8733	4/21/2022
	1	1	1	4,000	D	X															
Manahawkin	1	1	1	4,000	G	X							3,824							H7835	4/21/2022
	1	1	1	4,000	D	X															
Ocean Twp.	1	1	1	4,000	G	X						X	10,572							H8736	7/7/2021
	1	1	1	4,000	D	X															
Sand Hill	1	1	1	4,000	G	X						X	2,611							H1554	4/21/2022
	1	1	1	4,000	D	X															
Sayreville	1	1	1	4,000	D	X				X		X									
Toms River	1	1	1	10,000	G		X						14,599							H7836	7/7/2021
	1	1	1	4,000	D	X				X											
Wall Twp.	1	1	1	6,000	G	X				X			14,918							H2045	7/7/2021
	1	1	1	4,000	D	X				X											
Washington Twp.	2	2	1	6,000	G	X						X	3,963							H8739	5/13/2018
				6,000	G	X															
	1	1	1	6,000	D	X															
West Amwell	1	1	1	4,000	G	X				X		X	1,912							H8016	4/21/2022
	1	1	1	4,000	D	X				X											
West Trenton	1	1	1	4,000	G	X				X		X	9,446							H8735	4/21/2022
	1	1	1	4,000	D	X				X											

* Test Not Needed per Monthly Usage

Stage I Permit (R-GP-014)

Stage II Permit (R-GP-004)

NOTE: Air to Liquid Volume Ratio test is only required on vacuum assisted systems. Balanced systems do not require this test.

ATTACHMENT # 1
T2546 VAPOR RECOVERY SYSTEMS
GASOLINE TANKS FOR NJDOT
SOUTH REGION

Last Updated: 8/20/2018

LOCATION	QUANTITY			TANK SIZE	TYPE OF FUEL	AST	UST	STAGE II VAPOR RECOVERY SYSTEMS					AVERAGE MONTHLY OUTPUT (Jan 2016 - Aug 2017)	TESTS TO BE PERFORMED & FREQUENCY					FACILITY ID NUMBER	PERMIT EXPIRES
														Balance Systems			Vacuum Assisted Systems			
	Tanks	Dispensers	Nozzles per Dispenser					Gasboy Astra System	"U" Fuel Tank w/Suction Fuel Pump	Gravity System	(Submersible Pump w/Dispenser)	Other or No Stage II		CARB TP-201.3	CARB TP-201.2B	CARB TP-201.4	CARB TP-201.5			
														Static Pressure Performance Test (Pressure Decay)	Pressure / Vacuum Vent Valve Test	Dynamic Back Pressure Test (Flow & Blockage)	Air to Liquid Volume Ration Test	Vacuum Integrity Test (Healy Systems)		
Bordentown	2	2	1	6,000	G	X				X		32,242	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H4531	7/7/2021	
				6,000	G	X				X			12 MO.	12 MO.	36 MO.	12 MO.	12 MO.			
Bridgeport	1	1	1	4,000	D	X						1,338						H5517	4/21/2022	
				4,000	G	X				X			*	*	*	*	*			
Buena	1	1	1	6,000	G	X					X	962	12 MO.	12 MO.				H7044	7/13/2016	
				4,000	D	X														
Cherry Hill	2	1	2	6,000	G	X						10,942						H8727	7/7/2021	
				6,000	G	X														
Cumberland	1	1	1	6,000	D	X						2,050						H8831	4/21/2022	
				4,000	G	X				X			*	*	*		*			
Deepwater	1		1	4,000	D	X		X			X	4,851	*	*	*		*	H8732	4/21/2022	
				4,000	G	X														
Deptford	1	1	1	6,000	G	X		X		X		15,690	12 MO.	12 MO.	36 MO.			H8734	7/7/2021	
				4,000	D	X		X												
Edgewater Park	1	1	1	6,000	G	X					X	4,881	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H4500	4/19/2022	
				6,000	D	X														
Elmer	1	1	1	4,000	G	X						5,215	12 MO.	12 MO.				H6502	7/13/2016	
				4,000	D	X														
Folsom	1	1	1	4,000	D	X			X											
Glassboro	1	1	1	4,000	G	X		X			X	3,464	*	*	*		*	H5518	4/19/2022	
				4,000	D	X		X												
Mays Landing	1	1	1	6,000	G	X					X	10,313	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H7000	3/26/2019	
				6,000	D	X														
Middle Township	1	1	1	4,000	G	X					X	4,946	*	*	*		*	H7316	4/21/2022	
				4,000	D	X														
Mount Laurel	1	1	1	6,000	G	X					X	9,232	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8731	7/7/2021	
				4,000	D	X														
Pennsauken	1	1	1	4,000	G	X			X		X	3,892	*	*	*		*	H5017	4/21/2022	
				4,000	D	X			X											
Petersburg	1	1	1	4,000	G	X					X	2,768	*	*	*		*	H7317	4/21/2022	
				4,000	D	X														
Pomona	1	1	1	4,000	G	X			X			7,439	12 MO.	12 MO.				H7046	4/21/2022	
				2,000	D	X		X												
Southampton	1	2	2	4,000	G	X					X	13,291	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8830	4/20/2017	
				4,000	D	X														
Vineland	1	1	1	8,000	G		X			X		6,184	12 MO.	12 MO.	36 MO.			H7513	4/10/2020	
				8,000	D		X													
West Berlin	1	1	1	6,000	G	X					X	7,063	*	*	*		*	H5018	4/20/2022	
				4,000	D	X														
West Deptford	1	1	1	4,000	G	X					X	9,551	12 MO.	12 MO.	36 MO.	12 MO.	12 MO.	H8730	7/7/2021	
				4,000	D	X														

* Test Not Needed per Monthly Usage

Stage I Permit (R-GP-014)

Stage II Permit (R-GP-004)

NOTE: Air to Liquid Volume Ratio test is only required on vacuum assisted systems. Balanced systems do not require this test.