BULLETIN NO.1-AMENDMENT TO DRAWING E-701

Bulletin NO.1 amends drawing E-701 to include switchboard electrical load recording tables for switchboards MSS-A and MSS-B. Load recordings were taken on 04/01/2026-05/01/2026. The tables summarize the existing demand load and new anticipated load per the electrical drawings, with total load expressed as a percent of each switchboard's capacity. Metering was performed at the switchboard level rather than at the downstream branch panels. The downstream panels serving the area of work are in corridor spaces where metering equipment installation would create a hazard. New loads added under this scope for panels N-C-1D, C-E-1Y, and LS-E-1E are fed from switchboard MSS-A. New loads for panel N-E-1E are fed from switchboard MSS-B. The new load values reflected in each switchboard's load summary table represent only the additional load introduced by this project scope.