STATEMENT OF WORK
EATON Switch Gear Preventative Maintenance Services

1. Purpose

   This procurement is for services to perform an annual preventative maintenance of the EMALS switchgear GO#: SMH43914-001 with four option years. Equipment is located at Naval Air Warfare Center Aircraft Division Lakehurst, Highway 547 Bldg. 685, Joint Base MDL, NJ 08733.

2. Tasks

   Perform one preventative maintenance of the 15kV Medium Voltage Switchgear per year with 4 additional option years. The switch gear contains the following:

   - 15kV Medium Voltage Disconnect Switch
   - 150VCP-TR25 1200A Vacuum Circuit Breaker
   - FP5200 Relay

   Upon completion, the contractor shall provide a field service report of all the findings, test data, and recommendations.

3. Requirements

   - Be an authorized EATON Electrical Distributor
   - Able to schedule maintenance with 4 weeks' notice.
   - Perform all the necessary preventative maintenance in one visit.
   - Hours to perform maintenance shall be from 0700-1700
   - Repair all minor deficiencies on the spot at no additional cost.
   - Any major repair or replacement parts shall be quoted seperately.
   - Shall be able to meet all personnel and vehicle Government site entrance requirements.
     a. The company shall provide information for the Short Term Entry Authority List (EAL) one at least 3 business days prior to entrance for a background check.

4. Deliverables

   - CDRL A001 - Field Service Report