AIR FORCE MATERIEL COMMAND | 4 | 3 | 2 | 1 TINKER AFB, OK



NOTE: CONDUIT½" w/3-#12

LEGEND

- NEW 250W, MH, EXPLOSION PROOF
- OLD LIGHT REMOVED, BOX COVERED
- $ SINGLE POLE TOGGLE SWITCH
- NEW SINGLE PAC LED EXIT SIGN w/TWIN BEAM EMERGENCY LIGHTS. EMERGENCY BATTERY PACK MOUNTED ON EXTERIOR WALL.
- 120V-20A DUPLEX RECEPTICAL
- 4" SQ J-BOX
- NEW CONTROL FOR EXITS

REVISIONS

SYMBOL	DESCRIPTION	DATE	APPROVED

CORROSION ENGINEER:	DATE:
REVIEWED BY:	DATE:
FIRE DEPARTMENT:	DATE:
SAFETY:	DATE:
INDUSTRIAL HYGIENE:	DATE:
ENVIRONMENTAL ENGINEER:	DATE:
ASBESTOS EVALUATION:	DATE:
EMC:	DATE:
COMMUNICATIONS:	DATE:
USING AGENCY:	DATE:
REVIEWED BY:	DATE:
DEM:	DATE:
REVIEWED BY:	DATE:
CHIEF ENGINEER:	DATE:
BASE CIVIL ENGINEER	DATE:
DESIGNED BY:	DATE:
DRAWN BY:	DATE:
CHECKED BY:	DATE:
REVIEWED BY:	DATE:
CHIEF ENG DESIGN	DATE:

AIR FORCE MATERIEL COMMAND
72d CIVIL ENGINEERING SQUADRON

ELECTRICAL PLAN

TINKER AIR FORCE BASE, OKLAHOMA

REPLACE ELECTRICAL
IN PAINT SHOP, BLDG 1
WWYK 950213 D.O.5103

CADD FILE NUMBER:
ZFA :
SHEET REF NO: E-1
ARCHIVAL DATE:
TAPE NO:
SHEET 1 OF 1

SCALE:
DESIGN GROUP:
DATE: 10/01/97
DRAWING NUMBER:
DEF-

BIN NO: | FILE NO:

5 | 4 | 3 | 2 | 1