Prepared by
ALARMSpecialists, Inc

VA Hospital - Grand Junction - Parking Garage - Battery and Panel List - August 22, 2025									
Battery Group	Location	Panel Voltage	Charging Voltage	Voltage	AH Rating	OK	FAIL	Size	Comments
1	Electrical Room 104 Panel	119.0 VAC	27.7 VDC	13.6 VDC	17 AH		X	55.0Ah	23-Mar
				13.6 VDC	17 AH		X	55.0Ah	
2	Electrical Room 104 BPS 1	119.0 VAC	26.1 VDC	12.6 VDC	0 AH		X	9.0Ah	
				12.6 VDC	0 AH		X	9.0Ah	23-Mar

Prepared by
ALARMSpecialists, Inc

VA Hospital - Grand Junction - Bldg 5 - Battery and Panel List - August 22, 2025									
Battery Group	Location	Panel Voltage	Charging Voltage	Voltage	AH Rating	OK	FAIL	Size	Comments
1	Basement Panel	118.7 VAC	27.7 VDC	13.5 VDC	39 AH	X		55.0Ah	25-Feb
				13.6 VDC	40 AH	X		55.0Ah	
2	Basement BPS (ACPS) - Lower CAB of FACP	118.7 VAC	27.8 VDC	12.8 VDC	2.7 AH		X	12.0Ah	
				12.7 VDC	2.7 AH		X	12.0Ah	23-Mar

Prepared by
ALARMSpecialists, Inc

VA Hospital - Grand Junction - Bldg 6 - Battery and Panel List - August 22, 2025									
Battery Group	Location	Panel Voltage	Charging Voltage	Voltage	AH Rating	OK	FAIL	Size	Comments
1	Basement Panel	121.0 VAC	27.7 VDC	13.5 VDC	38 AH	X		55.0Ah	25-Feb
				13.1 VDC	32 AH	X		55.0Ah	
2	Basement BPS (bottom of FACP cabinet)	121.0 VAC	27.4 VDC	12.6 VDC	0 AH		X	12.0Ah	23-Mar
				12.7 VDC	0 AH		X	12.0Ah	

Prepared by
ALARMSpecialists, Inc

VA Hospital - Grand Junction - Bldg 33 - Battery and Panel List - August 22, 2025									
\	Location	Panel Voltage	Charging Voltage	Voltage	AH Rating	OK	FAIL	Size	Comments
1	Panel	119.0 VAC	27.7 VDC	13.5 VAC	5 AH		X	50 AH	23-Mar
				13.5 VAC	7.5 AH		X	50 AH	
2	BPS	119.1 VAC	27.8 VDC	13.1 VDC	7.8 AH	X		12 AH	22-Dec
				13.0 VDC	7.6 AH	X		12 AH	

Prepared by
ALARMSpecialists, Inc

VA Hospital - Grand Junction - Bldg 37 - Battery and Panel List - August 22, 2025									
Battery Group	Location	Panel Voltage	Charging Voltage	Voltage	AH Rating	OK	FAIL	Size	Comments
1	Room 122 BPS	119.5 VAC	27.6 VDC	13.0 VDC	1.9 AH		X	12 AH	23-Jan
				12.8 VDC	1.9 AH		X	12 AH	