Project Title: REPLACE HVAC UNITS, BLDG 582, NAVAL AIR STATION OCEANA VIRGINIA BEACH, VA

Solicitation / RFP#: N4008526R0172 - PPI Cut Off Date: 11-June-2026

PPI No.	Offeror	Date Submitted	REFERENCE				QUESTION	GOVERNMENT RESPONSE	Amend No.
			Page	Section	Para.	Dwg #			
12							Please confirm that a Level 2 QC/SSHO os reuqired of this contract since there are no specifications	See Scope of Work 2. GENERAL, 2.1. Level 2 or Level 3 is acceptable.	**0004**
13							Can QC/SSHO/Superintendent be the same individual?	See Scope of Work 2. GENERAL, 2.1. Level 2 or Level 3 is acceptable.	**0004**
14							Will a QC & site specific AP Plan be required to be submitted under this contract?	Yes.	**0004**
15							Please confirm that DDC Controls is not a requirment of this RFP. If DDC Controls is a requirment, please advise whose controls are currently in building.	DDC controls are not required. Split systems have standalone controls.	**0004**
16						A-101	Where the new ACCU-1/DSS-1 is to be located, there is an exisiting MRCOOL ductless mini split system occupying that location. Please advise direction with what to do with exisiting MRCOOL DSS as for alternate ACCU-1/DSS-1 location	Please see attached BLDG0582-1848813_M-101.	**0004**
17							Is temporary heating/cooling a requirement of the RFP?	Temporary heating/cooling is not required.	**0004**