

**STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HARBORS**

**ADDENDUM NO. 2
FOR
PAVEMENT REPAIRS AT VARIOUS LOCATIONS
KAWAIHAE HARBOR,
ISLAND OF HAWAII
PROJECT NO. Q50228**

June 19, 2026

This Addendum shall make the following amendment(s) to the Solicitation:

A. NOTICE TO BIDDERS

1. Prospective bidders are **hereby notified** that the bid opening, scheduled for **June 25, 2026, at 2:00 p.m., Hawaii Standard Time (HST)**, is **HEREBY POSTPONED** until **July 9, 2026, at 2:00 p.m., HST**.

The attached **NOTICE TO BIDDERS** dated **6/19/2026**, shall be incorporated and made a part of the **NOTICE TO BIDDERS**.

The following is provided for information.

B. RESPONSE TO REQUEST FOR INFORMATION (RFI'S/QUESTIONS)

1. The attached **RESPONSE TO REQUEST FOR INFORMATION** is provided for information.

Please acknowledge receipt of this **ADDENDUM NO. 2** by recording the date of its receipt in the space provided on **PAGE P-4** of the Proposal.



DREANALEE K. KALILI

Deputy Director of Transportation for Harbors

NOTICE TO BIDDERS
Hawaii Revised Statutes (HRS),
Chapter 103D

The receiving of bids for **PAVEMENT REPAIRS AT VARIOUS LOCATIONS, KAWAIHAE HARBOR ON THE ISLAND OF HAWAII, PROJECT NO. Q50228**, will begin as of the HiePRO Release Date. Bidders shall register and submit complete bids through HiePRO only. Refer to the following HiePRO link for important information on Vendor Registration: <https://hiepro.ehawaii.gov/welcome.html>.

The solicitation, specifications, proposal, and additional documents designated or incorporated by reference shall be available in HiePRO.

HiePRO OFFER DUE DATE & TIME scheduled for June 25, 2026, at 2:00 p.m., Hawaii Standard Time (HST), is **HEREBY POSTPONED** until **July 9, 2026**, at 2:00 p.m., HST.

Bidders shall submit and upload the complete proposal to HiePRO prior to the offer due date and time. Proposals received after said due date and time shall not be considered.

Any additional support documents explicitly designated as confidential and/or proprietary shall be uploaded as a separate file to HiePRO. Bidders shall not include confidential and/or proprietary documents as part of their proposal. The record of each bidder and their respective proposal shall be open to public inspection. **FAILURE TO UPLOAD THE PROPOSAL TO HiePRO SHALL BE GROUNDS FOR REJECTION.**



DREANALEE K. KALILI

Deputy Director of Transportation for Harbors

RESPONSE TO REQUEST FOR INFORMATION (RFI'S/QUESTIONS)

1. Question: On page 10-12 of the Specifications Part II Technical Provisions, Item 5 - Type "D" Repairs. Calls for "placing new 3-inch thick SMA pavement". Stone Matrix Asphalt (SMA) pavement is not available nor produced on Hawaii Island.

We request approval to use PMA Mix No. IV in lieu of SMA. as PMA Mix No. IV is a more readily available alternative on Hawaii Island.

Answer: No, PMA Mix No. IV is not approved as a suitable alternative. An approved alternative would be PMA Mix No. III which is primarily used in heavy-duty applications such as airfields and harbors.