



June 3, 2026

Dear Sir/Madam:

Attached is Addendum No.1 for SEPTA's Sealed Bid No. 26-00105-AJEB Traction Power Substation Rehabilitation Program – Contract 5 Broad, Loudon, Park and Castor Substations Project. **The Proposal Due Date remains unchanged on Wednesday, July 15, 2026 by 11AM.**

Any inquiries regarding this bid must be directed to Justin Benante of the Procurement and Supply Chain Management Department at (215) 580-7022.

Sincerely,

*Justin Benante*

Justin Benante  
Sr. Contract Administrator  
Procurement & Supply Chain Management Dept.

**SEALED BID No. 26-00105-AJEB**

**Traction Power Substation Rehabilitation Program – Contract 5 Broad, Loudon, Park and Castor Substations Project**

**ADDENDUM No. 1**

To All Bidders:

The following constitutes Addendum No. 1 to SEPTA's **Sealed Bid No. 26-00105-AJEB Traction Power Substation Rehabilitation Program – Contract 5 Broad, Loudon, Park and Castor Substations Project**. Addendum No. 1 must be acknowledged by inserting the date on the Addenda Response form. Failure to do so may render a bidder's proposal as non-responsive. Addendum No. 1 must be acknowledged by inserting the date of the Addendum within Attachment 4: ADDENDUM ACKNOWLEDGEMENT SHEET of the Bid Package. Failure to do so may render a bidder's proposal as non-responsive.

Questions and Answers issued with this Addendum No. 1 are hereby incorporated by reference and made part of the Terms and Conditions of this project

**A. General**

1. N/A

**B. Specifications,**

1. N/A

**C. Drawings & Attachments**

1.N/A

**D. Questions & Answers**

Please see answers in **RED** below:

Can SEPTA please clarify:

1. What level of protective clothing is required for site access? SEPTA stated that "FR Clothing" was required. Please confirm if this must be: **All garments will meet NFPA 70E 2024 guidelines.**
  - a. NFPA 2112 Flame-Resistant (FR) compliant clothing
  - b. AR (arc-rated in accordance with NFPA 70E / ASTM F1506)
  - c. dual-rated protective clothing (AR and FR)
2. If arc resistance is required, what NFPA 70E PPE category of arc rating is required? **Category 2, Arc Rating 8**
3. If there is an ankle height and/or EH marking requirement for the work boots? **EH Marking is required**