AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.	1. CONTRACT ID CODE	PAGE 1 OF PAGES 2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NUMBER	5. PROJECT NUMBER (if applicable)
0002			0

6. ISSUED BY	CODE	7. ADMINISTERED BY (If other than Item 6)	CODE
Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667		Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667	

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NUMBER
To all Offerors/Bidders		36C24626Q0418
	X	9B. DATED (SEE ITEM 11)
	☐	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended, [ ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 07-14-2026 15:00 EDT

12. ACCOUNTING AND APPROPRIATION DATA (If required)

See CONTINUATION Page

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to extend the response due date and provide drawings and answers to questions that were addressed for solicitation 36C24626Q0418.
A. Response due date is hereby extended to 15:00 EST, July 14, 2026.
B. Questions and answers are added below
C. Drawings are posted as attachments.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Jamie Sullivan Contracting Officer	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION PAGE

OR lights and booms follow-up	
Qustion	**Answer**
1. We see the CAD PDF documents but could we have the actual drawings? Could you please provide the following CAD drawings: a. Electrical- Panel Schedule b. Structural (Above Deck) c. Structural Stamped Drawings of the Current B&L structure d. Plumbing: Med GAS e. Architectural	Please see the attached drawings
2. We see that there is mention/question & answers surrounding the HD cameras and the 4K monitors. Because there is a SEPARATE integration requirement, shouldn't those cameras and monitors be on the integration solicitation and NOT this requirement?	Yes, the cameras and 4k monitors are part of a separate solicitation for OR integration not this requirment for OR lights and booms.
3. Thank you for documenting the mistake in regard to the med/gas and duplex counts. Based on the walk thru, we are still seeing discrepancies though. It is our understanding there would be (7) med/gas and (5) duplex (vs the 9 and 4 mentioned). Below we are including what was requested. Can you please verify and provide updated count? This is imperative because additional counts would be significantly more of a cost to add then what was initially budgeted for.	For the Anesthia Boom: 2- Oxygen, 2 - Medical Air, 2 - N2O, 1 - WAGD, 2 - VAC, 4 - 20A Duplex , 2 - Data For the Equipment Boom: 1 - Oxygen, 1 - Medical Air, 1 - CO2, 2 - VAC, 8 - 20A Duplex, 4 - data
4. If stamped structural drawings are not available, and/or if the proposed boom system exceeds a 5% increase over the existing supported load, will the awarded contractor be responsible for providing updated, stamped structural calculations and drawings prepared by a licensed structural engineer? If so, please clarify whether this requirement is included within the project's scope of work.	Drawings will be provided